

SELECT ENVIRONMENTAL SOLUTIONS INC.
110 Forest Road
Robesonia, PA 19551
Office (610) 589-4023 Cell (717) 228-7419
selectenvironmental@gmail.com

June 22, 2021

Bernville Borough
P.O. Box 40
Bernville, PA 19506

Re: Bernville Borough Wastewater Treatment Plant
NPDES Permit No. PA 0024023
May 2021 – Monthly Operation and Maintenance Report

Dear Mr. Strunk:

We are pleased to report that there were no Final Effluent water quality violations during the month of May, 2021. Copies of the following information, which are submitted to the Pennsylvania Department of Environmental Protection (PADEP) on behalf of the Bernville Borough, are enclosed for your files. All forms can now be seen online via PADEP's website via the eDMR.

- Discharge Monitoring Report Supplemental Forms
- Monthly Maintenance Log

A brief summary of the monthly flow data is as follows:

Average, in gallons per day	=	170,200
Maximum, in gallons per day	=	216,300
Rainfall for May 2021	=	3.77"

Routine Maintenance/Events:

Attached is the sheet showing maintenance jobs performed in May.

Mr. Rehab completed all required tasks. We will monitor the next few rain events and if we need to do more I and I work to look for more leaks.

If you have any questions, require more information or wish to comment on the above information, please contact me at 717-228-7419.

Sincerely,



Michael T. Kreiser
Owner/Operator

cc James McCarthy, McCarthy Engineer

May 2021 Maintenance - Job Completed

Bernville W.W.T.P.

Date:

5/4	Suburban Collected Weekly Samples and both generators were operated
5/11	
5/18	
5/25	
5/3	Washed walls of SBR 1
5/4	Washed walls of SBR #2
5/5	Backflushed SBR #1
5/6	Backflushed SBR #2
	UV auto switch to channel #1. Drained and cleaned #2.
5/7	Washed walls of SBR #1
	Installed PEQ High Level Float
5/10	Washed walls of SBR #2
5/12	Washed walls of SBR #2
5/13	UV Auto Switch to Channel #2. Drained and cleaned #1
	Washed walls SBR #1
5/14	Added microbes to digester
5/17	Backflushed SBR #1
5/18	Washed walls of both SBRs
5/20	Washed walls SBR #2
	UV auto switch to channel #1. Drained and cleaned #2.
5/21	Added microbes to digester
5/25	Washed walls of SBR #1
5/27	UV Auto Switch to Channel #2. Drained and cleaned #1
	Greased blowers & pumps & checked oil levels
	Washed walls of SBR 1
5/28	Added microbes to digester