

SELECT ENVIRONMENTAL SOLUTIONS INC.
110 Forest Road
Robesonia, PA 19551
Home (610)589-4023 Cell (717) 228-7419
selectenvironmental@gmail.com

June 9, 2021

Bernville Borough
P.O. Box 40
Bernville, PA 19506

**Re: Bernville Borough Water Treatment Plant
May 2021 – Monthly Operation and Maintenance Report**

Dear Mr. Strunk:

We are pleased to report that there were no water quality violations during the month of May, 2021. Copies of the following information, which were submitted to the Pennsylvania Department of Environmental Protection (PADEP) on behalf of Bernville Borough, were emailed to you for your files.

- Monthly DWELR Reports for the two Wells

A brief summary of the monthly flow data is as follows:

2021			
May	Well		Total Daily Gallons
	4	3	
Average	83,209	102,976	83,847
Total	2,496,283	102,976	2,599,259
Min	1,142	102,976	1,142
Max	169,113	102,976	169,113

Routine Maintenance/Events:

- Performed daily well inspections as per the contract
- Rotated Wells daily
- Weekly duties as per the contract
- Monthly duties as per the contract

Non Routine Maintenance/Events:

- May 6, Staff changed the water meter and flushed the line at 340 N. Main St.
- May 14, Staff turned on the water at the garage for Friedens Church.

We have been having Met Ed voltage issues from the end of May until now. They have been working on it this week but has been causing us to not be able to run the well. Bernville should consider having a generator installed at Well 4. Well 4 is the better quality that doesn't put as much manganese into the system.

If you have any questions, require more information or wish to comment on the above information, please contact me at 717-228-7419.

Sincerely,

Michael T. Kreiser
Owner/Operator